

Jeffers 2021 Drinking Water Report

Making Safe Drinking Water

Your drinking water comes from a groundwater source: purchased water from Red Rock Rural Water System.

Jeffers works hard to provide you with safe and reliable drinking water that meets federal and state water quality requirements. The purpose of this report is to provide you with information on your drinking water and how to protect our precious water resources.

Contact Lance Holmen, Public Works Superintendent, at 507-830-1303 or lancegholmen@yahoo.com if you have questions about Jeffers's drinking water. You can also ask for information about how you can take part in decisions that may affect water quality.

The U.S. Environmental Protection Agency sets safe drinking water standards. These standards limit the amounts of specific contaminants allowed in drinking water. This ensures that tap water is safe to drink for most people. The U.S. Food and Drug Administration regulates the amount of certain contaminants in bottled water. Bottled water must provide the same public health protection as public tap water.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Jeffers Monitoring Results

This report contains our monitoring results from January 1 to December 31, 2021.

We work with the Minnesota Department of Health to test drinking water for more than 100 contaminants. It is not unusual to detect contaminants in small amounts. No water supply is ever completely free of contaminants. Drinking water standards protect Minnesotans from substances that may be harmful to their health.

Learn more by visiting the Minnesota Department of Health's webpage [Basics of Monitoring and testing of Drinking Water in Minnesota](https://www.health.state.mn.us/communities/environment/water/factsheet/sampling.html) (<https://www.health.state.mn.us/communities/environment/water/factsheet/sampling.html>).

How to Read the Water Quality Data Tables

The tables below show the contaminants we found last year or the most recent time we sampled for that contaminant. They also show the levels of those contaminants and the Environmental Protection Agency's limits. Substances that we tested for but did not find are not included in the tables.

Monitoring Results – Regulated Substances

LEAD AND COPPER – Tested at customer taps.

| Contaminant (Date, if sampled in previous year) | EPA's Ideal Goal (MCLG) | EPA's Action Level | 90% of Results Were Less Than | Number of Homes with High Levels | Violation | Typical Sources |
|---|-------------------------|--------------------------------|-------------------------------|----------------------------------|-----------|----------------------------------|
| Lead | 0 ppb | 90% of homes less than 15 ppb | 1.75 ppb | 0 out of 5 | NO | Corrosion of household plumbing. |
| Copper | 0 ppm | 90% of homes less than 1.3 ppm | 0.08 ppm | 0 out of 5 | NO | Corrosion of household plumbing. |

CONTAMINANTS RELATED TO DISINFECTION – Tested in drinking water.

| Substance (Date, if sampled in previous year) | EPA's Ideal Goal (MCLG or MRDLG) | EPA's Limit (MCL or MRDL) | Highest Average or Highest Single Test Result | Range of Detected Test Results | Violation | Typical Sources |
|---|----------------------------------|---------------------------|---|--------------------------------|-----------|--|
| Total Trihalomethanes (TTHMs) (2019) | N/A | 80 ppb | 38.3 ppb | N/A | NO | By-product of drinking water disinfection. |
| Total Haloacetic Acids (HAA) (2019) | N/A | 60 ppb | 29 ppb | N/A | NO | By-product of drinking water disinfection. |
| Total Chlorine | 4.0 ppm | 4.0 ppm | 1.3 ppm | 0.95 - 1.51 ppm | NO | Water additive used to control microbes. |

Total HAA refers to HAA5

Lead in Drinking Water

You may be in contact with lead through paint, water, dust, soil, food, hobbies, or your job. Coming in contact with lead can cause serious health problems for everyone. There is no safe level of lead. Babies, children under six years, and pregnant women are at the highest risk.

Lead is rarely in a drinking water source, but it can get in your drinking water as it passes through lead service lines and your household plumbing system. Jeffers is responsible for providing high quality drinking water, but it cannot control the plumbing materials used in private buildings.

Read below to learn how you can protect yourself from lead in drinking water.

1. **Let the water run** for 30-60 seconds before using it for drinking or cooking if the water has not been turned on in over six hours. If you have a lead service line, you may need to let the water run longer. A service line is the underground pipe that brings water from the main water pipe under the street to your home.
 - You can find out if you have a lead service line by contacting your public water system, or you can check by following the steps at: <https://www.mprnews.org/story/2016/06/24/npr-find-lead-pipes-in-your-home>
 - The only way to know if lead has been reduced by letting it run is to check with a test. If letting the water run does not reduce lead, consider other options to reduce your exposure.
2. **Use cold water** for drinking, making food, and making baby formula. Hot water releases more lead from pipes than cold water.
3. **Test your water.** In most cases, letting the water run and using cold water for drinking and cooking should keep lead levels low in your drinking water. If you are still concerned about lead, arrange with a laboratory to test your tap water. Testing your water is important if young children or pregnant women drink your tap water.
 - Contact a Minnesota Department of Health accredited laboratory to get a sample container and instructions on how to submit a sample:
[Environmental Laboratory Accreditation Program \(https://eldo.web.health.state.mn.us/public/accreditedlabs/labsearch.seam\)](https://eldo.web.health.state.mn.us/public/accreditedlabs/labsearch.seam)
The Minnesota Department of Health can help you understand your test results.
4. **Treat your water** if a test shows your water has high levels of lead after you let the water run.
 - Read about water treatment units:
[Point-of-Use Water Treatment Units for Lead Reduction \(https://www.health.state.mn.us/communities/environment/water/factsheet/poulead.html\)](https://www.health.state.mn.us/communities/environment/water/factsheet/poulead.html)

Learn more:

- Visit [Lead in Drinking Water \(https://www.health.state.mn.us/communities/environment/water/contaminants/lead.html\)](https://www.health.state.mn.us/communities/environment/water/contaminants/lead.html)
- Visit [Basic Information about Lead in Drinking Water \(http://www.epa.gov/safewater/lead\)](http://www.epa.gov/safewater/lead)
- Call the EPA Safe Drinking Water Hotline at 1-800-426-4791. To learn about how to reduce your contact with lead from sources other than your drinking water, visit [Common Sources \(https://www.health.state.mn.us/communities/environment/lead/fs/common.html\)](https://www.health.state.mn.us/communities/environment/lead/fs/common.html).